

Landings

Landings should be available:

- At the top and bottom of the ramp.
- Whenever there is a change in the direction of a ramp

The landing should:

- Be at least as wide as the widest ramp run leading to it
- Have a minimum length of 1500 mm (59 inches).
- Have a minimum size not less than 15000 mm x 15000 mm (59 inches x 59 inches) if served by a doorway.

Source: Accessible Design for the Built Environment, Registered trade-mark of Canadian Standards Association, 2004, Ontario.

